



KERALA WATER AUTHORITY

PULIKKEEZHU, THIRUVALLA

Telephone No. 0469 2600833, Email : kwaqedlplkz@gmail.com

WATER ANALYSIS REPORT

Report No: 2625/PL.KZ/05/2022(mb)

Date: 21.05.2022

Customer Name & Address
 Holy Mary Central School
 Peringala P.O
 Kayamkulam

1. Date of Receipt
2. Date of Sampling
3. Time of Sampling
4. Sampling done by
5. Sample Code
6. Source of Sample
7. Sample Quantity
8. Test performing dates

18.05.2022
 18.05.2022
 12.30 PM
 Customer
 2022 QCSDI PLKZ P2769
 OPEN WELL
 100 ml
 From: 18.05.2022 to 21.05.2022

BACTERIOLOGICAL ANALYSIS


Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Coliforms	Shall not be detected/100 ml	MPN	93
2	E-coli	Shall not be detected/100 ml	MPN	NH

Remarks:-

NB - The results stated above related only to the samples submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Verified By

Name: JINESH THANKAPPAN
 Bacteriologist



End of Report

Authorized by

Name: DHANYA P P
 Bacteriologist

Page 1 of 1